

E13-2014-97

N. Azaryan<sup>1</sup>, V. Batusov<sup>1</sup>, J. Budagov<sup>1</sup>, V. Glagolev<sup>1</sup>,  
M. Lyablin<sup>1,\*</sup>, G. Trubnikov<sup>1</sup>, G. Shirkov<sup>1</sup>, J.-Ch. Gayde<sup>2</sup>,  
B. Di Girolamo<sup>2</sup>, D. Mergelkuhl<sup>2</sup>, M. Nessi<sup>2</sup>

THE PRECISION LASER INCLINOMETER LONG-TERM  
MEASUREMENT IN THERMO-STABILIZED CONDITIONS  
(FIRST EXPERIMENTAL DATA)

Submitted to "Particles and Nuclei, Letters"

---

<sup>1</sup> Joint Institute for Nuclear Research, Dubna

<sup>2</sup> European Organization for Nuclear Research (CERN), Geneva, Switzerland

\* E-mail: lyablin@jinr.ru

Азарян Н. и др.

E13-2014-97

Долговременные измерения прецизионного лазерного инклинометра в термостабилизированных условиях (первые экспериментальные результаты)

Прецизионный лазерный инклинометр протестирован в термостабилизированных условиях. Измерена угловая стабильность земной поверхности — 1 мкрад (время измерения 24 ч) и 7 нрад (время измерения 60 мин).

Работа выполнена в Лаборатории ядерных проблем им. В.П.Джелепова ОИЯИ.

Препринт Объединенного института ядерных исследований. Дубна, 2014

Azaryan N. et al.

E13-2014-97

The Precision Laser Inclinometer Long-Term Measurement in Thermo-Stabilized Conditions (First Experimental Data)

The Precision Laser Inclinometer was tested at thermo-stabilized conditions, and the ground angular stability of 1  $\mu$ rad (observation during 24 h) and 7 nrad (observation during 60 min) was measured.

The investigation has been performed at the Dzhelepov Laboratory of Nuclear Problems, JINR.

Preprint of the Joint Institute for Nuclear Research. Dubna, 2014

## INTRODUCTION

There are many tasks where the metrology control of the ground angular stability becomes of a principal necessity. In [1, 2], the Precision Laser Inclinometer (PLI) was proposed as a sensitive indicator of the ground motion. The PLI's signal was meant to be used for specialized set-up for laser beam direction stabilization. This paper shows the hardware scheme and the very first encouraging results obtained with a prototype installed in a transfer tunnel at CERN.

The PLI ground motion data, in an experimental environment such as ATLAS, may develop subdetectors relative displacements to be taken into account with the LHC total collision energy rise [4–7]. The ground motion could be considered when stabilization of a space location like the focus area of an accelerator as LHC is interesting for beams forming optics. There are some recent evidences of growing interest to the gravity constant measurement where detectors stability is of vital necessity [3]. In a new large project of CLIC, ILC scale the precision alignment and space stabilization of many accelerator units may need the ground oscillation data.

## THE PRECISION LASER INCLINOMETER

Unlike the previous Inclinometer scheme [1] used two platforms to position Inclinometer components, the new design tested used only one platform for compactness. It allowed one to decrease significantly the influence of deformation, caused by temperature variations, on the Inclinometer data stability.

Note, that for this experiment thermo-stabilization has been integrated to the Inclinometer. This represents a major upgrade of the previous Inclinometer design.

Figure 1 shows the principal scheme of an Inclinometer used.

The laser ray  $L$  from the laser source is sent on optical collimator. After the collimator the  $\varnothing 2$ -cm beam is directed with Mirror#1 on the Inclinometer's Sensitive Element (ISE). There, by Mirror#2 the beam is sent into a cuvette with liquid (see Side view of Fig. 1); after being reflected from liquid's surface, the beam moves backwards to meet Mirror#3 and further to enter the Duant Photoreceiver (DPr).




Fig. 1. The principal scheme of the Precision Laser Inclinometer

To increase the Inclinometer's angular resolution\*, the laser irradiation is focused (by the lens with 750 mm of focus distance) into  $\varnothing 50\text{-}\mu\text{m}$  spot on the DPr surface.

The cuvette inclination angle is registered by the dual photoreceiver. The DPr signal is recorded by the ADC in computer.

The Inclinometer scheme used two passive thermo-stabilizations:

— the perpendicular laser-ray direction with respect to the liquid surface: in this case, the external temperature variations leading to liquid's level change do not disturb the reflected ray direction;

— application of lens which focuses the ray on the Duant Photoreceiver: in this case, the ray transversal displacements between laser source and the lens do not change the lens's focus position.

### THE EXPERIMENTAL LOCATION

The experiment for determination of the Inclinometer long-term stability was installed in CERN's Transfer Tunnel#1 (TT1) (Fig. 2).

\*As shown in [8], the registered DPr signal  $\Delta U$  for laser spot displacement  $\delta$  is  $\Delta U \sim \delta/D$  with  $D$  as beam spot diameter on the DPr.



Fig. 2. The Transfer Tunnel general view in the experiment location area




Fig. 3. Precision Laser Incliner location in the Transfer Tunnel#1

The 140 m long TT1 is located at 10-m depth underground and has stable daily temperature of  $(16.4 \pm 0.1) ^\circ\text{C}$ .

The Incliner was positioned in the middle of the tunnel. The measurements of the tunnel *floor angular oscillations* have been made in the vertical plane containing the tunnel longitudinal axis, corresponding to the direction East–West preliminary.

Figure 3 shows the location and general view of the Incliner.

## THE EXPERIMENTAL RESULTS

Measurements of the angular oscillations of the TT1 floor have been performed during a period of a few days long.

Figure 4 demonstrates the day-long measurements record for the period of 21–22 June, 2014.

The day-long Inclinometer data spread is small and limited by the  $1 \mu\text{rad}$  wide interval.




Fig. 4. The record of the day-long angular oscillations of the TT1 floor




Fig. 5. The distribution of the TT1 floor angular inclinations measured for the A–B period of Fig. 4

Figure 5 shows the distribution of the Inclinometer angular measurements for 60 min long A–B interval of Fig. 4. For this case the  $\sigma_{\text{rms}}$  is found to be 7 nrad.

## CONCLUSION

The Precision Laser Inclinometer first measurements have been made in thermo-stabilized conditions and the achieved results are:

— the angular daily data spread reached with the Inclinometer is within the 1- $\mu$ rad band;

— for the single-taken short-period (60 min) A–B in Fig. 5 the Inclinometer angular spread is  $\sigma_{\text{rms}} = 7$  nrad.

**Acknowledgements.** The JINR group thanks BMBF (Germany) for the financial support.

## REFERENCES

1. *Batusov V. et al.* Laser Beam Fiducial Line Application for Metrological Purposes // Phys. Part. Nucl. 2009. V. 40, Iss. 1. P. 115–129.
2. *Budagov J. et al.* A Laser-Based Fiducial Line for High Precision Multipoint Alignment System // Part. Nucl. Lett. 2014. V. 11, No. 3. P. 286–293.
3. *Batusov V. et al.* The Laser Reference Line Method and Its Comparison to a Total Station in an ATLAS-Like Configuration // Ibid. P. 299–308.
4. *Batusov V., Budagov J., Lyablin M.* A Laser Sensor of a Seismic Slope of the Earth Surface // Part. Nucl. Lett. 2013. V. 10, No. 1. P. 43–48.
5. *Nakayama Y. et al.* Ground Motion Measurement at J-PARC // Proc. of EPAC 2006, Edinburgh, Scotland. P. 330–332.
6. *Budagov J., Lyablin M., Shirkov G.* The Search for and Registration of Superweak Angular Ground Motion. JINR Preprint E18-2013-107. Dubna, 2013.
7. *Quinn T. J.* Fundamental Constants: Measuring Big G // Nature. 2000. V. 408. P. 919–921.
8. *Batusov V. et al.* Photodetector Noise Limitations of the Laser Ray of the Space Location. JINR Preprint E13-2008-90. Dubna, 2008.

Received on December 16, 2014.

Редактор *В. В. Булатова*

Подписано в печать 25.12.2014.

Формат 60 × 90/16. Бумага офсетная. Печать офсетная.

Усл. печ. л. 0,75. Уч.-изд. л. 0,33. Тираж 245 экз. Заказ № 58441.

Издательский отдел Объединенного института ядерных исследований  
141980, г. Дубна, Московская обл., ул. Жолио-Кюри, 6.

E-mail: [publish@jinr.ru](mailto:publish@jinr.ru)

[www.jinr.ru/publish/](http://www.jinr.ru/publish/)